



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

July 25, 2013

PENNER MFG.INC.
DALE WALL
102 GRANT ST
PO BOX 503
AURORA NE 68818

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: PENNER MFG.INC.
Product Name: CASCADE BATHING SYSTEMS
Model Number(s): CASCADE 6900 SIT BATH:360010-X, 360010-XL, 361910-X, 360010-XW, 360030-1C, 360010-1L, 360010-1, 361910-1, 360010-1W, 362010-1, 362010-1L, 362010-X, 362010-XL.
CASCADE ALCOVE & ISLAND: 361010-1A, 361910-1I, 361910-XA, 361910-XI.
CASCADE ELETE 360020-1PE
CASCADE RESERVOIR: 370000-1W, 370000-1WL, 370000-XW, 370000-XLW
Product File No: 20130188

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2014.

This approval supersedes the approval issued on April 3, 2009 under product file number 20090144.

External cross connection control measures are not required for these devices because they contain integral air gaps that conform to ASME A112.1.2 and pipe applied atmospheric vacuum breakers that conform to ASSE 1001.

These devices also contain check valves; however no cross connection control credit was given for the check valves.

The department is in no way endorsing these products or any advertising, and is not responsible for any situation which may result from their use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail